

No EN.DZ.APM2.U2

EU Declaration of Conformity

issued under the sole responsibility of the manufacturer

The object of this declaration: Smart modular differential pressure transmitter APM-2.

Manufacturer: APLISENS S.A.,

ul. Morelowa 7, 03-192 Warszawa

We hereby declare under the sole responsibility, that the object of the declaration defined above comply with relevant Union harmonization legislation.

Smart modular differential pressure transmitters APM-2 in all versions comply with directives:

EMC – 2014/30/EU dated 26 February 2014

Conformity assessment procedure: module A.

The following standards were applied: EN 61326-1:2013, EN 61326-2-3:2013.

RoHS – 2011/65/EU dated 08 June 2011

Conformity assessment procedure: module A, according to Decision No 768/2008/EC of the European Parliament and of the Council.

The following standard was applied: EN IEC 63000:2018.

Smart modular differential pressure transmitters APM-2 in Ex versions comply with directive:

ATEX – 2014/34/EU dated 26 February 2014

Intrinsically safe versions of transmitters are marked with the following certificate marking:

II 1/2G Ex ia IIC T5/T4/T3 Ga/Gb II 1D Ex ia IIIC T100°C/T135°C/T155°C Da JSHP 22 ATEX 0051X

The following standards were applied: EN IEC 60079-0:2018, EN 60079-11:2012.

Conformity assessment procedure: module B. Notified Body no.2057, J.S Hamilton Poland Sp. z o.o. ul. Wyzwolenia 14, 41-103 Sienamowice Ślaskie

Explosion-proof versions of transmitters are marked with the following certificate marking:

II 1/2G Ex db ia IIC T5/T4/T3 Ga/Gb II 1D Ex ia ta IIIC T100°C/T135°C/T155°C Da JSHP 22 ATEX 0051X

The following standards were applied: EN IEC 60079-0:2018, EN 60079-1:2014, EN 60079-11:2012,

EN 60079-31:2014.

Conformity assessment procedure: module B. Notified Body no.2057, J.S Hamilton Poland Sp. z o.o. ul. Wyzwolenia 14, 41-103 Sienamowice Śląskie

Notification of quality assurance: Module D. Notified Body no.1453, Central Mining Institute, Plac Gwarków 1, 40-166 Katowice.

Warsaw, 24.10.2022

Adam Żurawski General Manager